



July 16, 2012

SFA SANIFLO INC.  
JOSE C. PACHAS  
105 NEWFIELD AVE SUITE B  
EDISON NJ 08837

Re: Description: MACERATING PUMP SYSTEM  
Manufacturer: SFA SANIFLO INC.  
Product Name: SANIPRO MACERATING PUMP  
Model Number(s): OO6 & SANIACCESS3  
Product File No: 20120196

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.30 (10) (b) 3. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2017.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The venting system of the connecting fixtures must conform to requirements of SPS 382.31 of the Wisconsin Administrative code
- The discharge pipe must connect to a sanitary drain system in accordance with SPS 382.30 (10) of the Wisconsin Administrative code.
- The venting system serving the macerating unit must conform to requirements of SPS 382.31 of the Wisconsin Administrative code, "vents for sumps".
- This product may serve a toilet, lavatory, shower and/or a bathtub with or without a shower.

This approval supersedes the approval issued on May 29, 2012 under product file number 20120196.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20120196.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson  
Plumbing Product Reviewer  
Phone: 608-266-6742  
Fax: 608-267-9566  
E-mail: jerry.thompson@wi.gov